## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

## FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

LISTING No. 7165-0075:177 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Fire-Lite Alarms, Inc., One Fire-Lite Place, Northford CT 06472-1653

Contact: Lawrence Flood (203) 484-1200

**DESIGN:** Models MS5210UD fire alarm control unit. Power-limited; non-coded, local, remote station

> and central station service; manual, automatic, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational

considerations. System components:

Control Unit MS-5210UD CAC-10F Class A Connector PRT-24 Printer Interface Module NAC-REM Bell/Relay Expander Module

XRM-24 Transformer

LED-10IM Annunciator Interface Module

DP-5210UD Front Cover

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

Listee's name, model number, electrical ratings, and UL Inc. Label MARKING:

APPROVAL: Listed as a fire alarm control unit for use with separately listed electrically compatible

initiating and indicating devices.

This control unit can generate the temporal code pattern fire alarm signal as required per

\*NFPA 72, 1996 Edition. Refer to manufacturer's Installation Manual for details.

NOTE: For Alarm Verification Feature, the maximum Retard/Rest/Restart shall be adjusted to 30

seconds or less.

\*Rev. 08-26-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**APRIL 10, 2002** Date Issued: Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager